

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
7/1/22	7.11			Yes
7/2/22	7.04			Yes
7/3/22	7.05			Yes
7/4/22	7.08			Yes
7/5/22	7.08			Yes
7/6/22	7.12	12.5		Yes
7/7/22	7.12			Yes
7/8/22	7.11			Yes
7/9/22	7.17			Yes
7/10/22	7.15			Yes
7/11/22	7.08			Yes
7/12/22	7.03			Yes
7/13/22	7.02	14.1		Yes
7/14/22	7.03			Yes
7/15/22	6.96			No
7/16/22	6.98			No
7/17/22	7.06			Yes
7/18/22	7.21			Yes
7/19/22	7.34			Yes
7/20/22	7.35	12.9		Yes
7/21/22	7.22			Yes
7/22/22	7.16			Yes
7/23/22	7.18			Yes
7/24/22	7.21			Yes
7/25/22	7.19			Yes
7/26/22	7.13			Yes
7/27/22	7.07			Yes
7/28/22	7.13			Yes
7/29/22	7.18			Yes
7/30/22	7.19			Yes
7/31/22	7.17			Yes

Entry Point

PWSID 4100359
 System name Corbett Water District
 Entry Point WTP-A Slow Sand Filter plant
 Sample Period Jul-22

Number of excursionsn during this month 2
 (count the number of days when any WQP was less than minimum required)

Total excursion during the previous 5 months 0

(Over 9 excursions in 6 months is a violation.
 Entry Point and Distribution excursions are culmulative

For OHA use only

Minimum Water Quality Parameters as set by

pH 7
 Alk 8 Alkanlinity
 PO4 Orthrophosphate
 Other

Print Name David Jacob

Signature David Jacob

Date 8/6/2022