

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
8/1/22	7.13			Yes
8/2/22	7.13			Yes
8/3/22	7.17	15.5		Yes
8/4/22	7.19			Yes
8/5/22	7.21			Yes
8/6/22	7.24			Yes
8/7/22	7.25			Yes
8/8/22	7.26			Yes
8/9/22	7.3			Yes
8/10/22	7.34	75		Yes
8/11/22	7.38			Yes
8/12/22	7.39			Yes
8/13/22	7.41			Yes
8/14/22	7.42			Yes
8/15/22	7.43			Yes
8/16/22	7.44			Yes
8/17/22	7.5	18.6		Yes
8/18/22	7.46			Yes
8/19/22	7.45			Yes
8/20/22	7.48			Yes
8/21/22	7.53			Yes
8/22/22	7.53			Yes
8/23/22	7.51			Yes
8/24/22	7.54	18		Yes
8/25/22	7.61			Yes
8/26/22	7.62			Yes
8/27/22	7.63			Yes
8/28/22	7.61			Yes
8/29/22	7.59			Yes
8/30/22	7.58			Yes
8/31/22	7.57	20		Yes

Entry Point

PWSID 4100359
 System name Corbett Water District
 Entry Point WTP-A Slow Sand Filter plant
 Sample Period Aug-22

Number of excursionsn during this month 0
 (count the number of days when any WQP was
 less than minimum required)

Total excursion during the previous 5 months 2
 (Over 9 excursions in 6 months is a violation.
 Entry Point and Distribution excursions are
 culmulative)

For OHA use only

Minimum Water Quality Parameters as set by
pH 7
Alk 8 Alkanlinity
PO4 Orthrophosphate
Other

Print Name David Jacob
 Signature David Jacob
 Date 9/6/2022