

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
9/1/22	7.61			Yes
9/2/22	7.55			Yes
9/3/22	7.57			Yes
9/4/22	7.6			Yes
9/5/22	7.62			Yes
9/6/22	7.6			Yes
9/7/22	7.57	18.2		Yes
9/8/22	7.62			Yes
9/9/22	7.64			Yes
9/10/22	7.68			Yes
9/11/22	7.71			Yes
9/12/22	7.72			Yes
9/13/22	7.7			Yes
9/14/22	7.64	18.7		Yes
9/15/22	7.63			Yes
9/16/22	7.62			Yes
9/17/22	7.61			Yes
9/18/22	7.59			Yes
9/19/22	7.59			Yes
9/20/22	7.57			Yes
9/21/22	7.53	19.1		Yes
9/22/22	7.57			Yes
9/23/22	7.58			Yes
9/24/22	7.58			Yes
9/25/22	7.59			Yes
9/26/22	7.56			Yes
9/27/22	7.55			Yes
9/28/22	7.54	18.7		Yes
9/29/22	7.57			Yes
9/30/22	7.61			Yes

Entry Point

PWSID 4100359
System name Corbett Water District
Entry Point WTP-A Slow Sand Filter plant
Sample Period Sep-22

Number of excursionsn during this month 0
(count the number of days when any WQP was
less than minimum required)

Total excursion during the previous 5 months 2

(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
culmulative)

For OHA use only

Minimum Water Quality
Parameters as set by

pH 7
Alk 8 Alkanlinity
PO4 Orthrophosphate
Other

Print Name David Jacob

Signature David Jacob

Date 10/2/2022