

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
10/1/22	7.64			Yes
10/2/22	7.62			Yes
10/3/22	7.59			Yes
10/4/22	7.6			Yes
10/5/22	7.58	18.3		Yes
10/6/22	7.57			Yes
10/7/22	7.57			Yes
10/8/22	7.55			Yes
10/9/22	7.46			Yes
10/10/22	7.41			Yes
10/11/22	7.43			Yes
10/12/22	7.47	21.52		Yes
10/13/22	7.52			Yes
10/14/22	7.6			Yes
10/15/22	7.62			Yes
10/16/22	7.61			Yes
10/17/22	7.6			Yes
10/18/22	7.56			Yes
10/19/22	7.53	20.8		Yes
10/20/22	7.5			Yes
10/21/22	7.45			Yes
10/22/22	7.44			Yes
10/23/22	7.45			Yes
10/24/22	7.5			Yes
10/25/22	7.55			Yes
10/26/22	7.59	14.5		Yes
10/27/22	7.65			Yes
10/28/22	7.77			Yes
10/29/22	7.79			Yes
10/30/22	7.81			Yes
10/31/22	7.85			Yes

Entry Point

PWSID 4100359
System name Corbett Water District
Entry Point WTP-A Slow Sand Filter plant
Sample Period Oct-22

Number of excursionsn during this month 0
(count the number of days when any WQP was less than minimum required)

Total excursion during the previous 5 months 2

(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are culmulative

For OHA use only

Minimum Water Quality Parameters as set by

pH 7 Alkanlinity
Alk 8 Orthrophosphate
PO4
Other

Print Name David Jacob
Signature David Jacob
Date 11/6/2022