

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
11/1/22	7.9			Yes
11/2/22	7.93	14.4		Yes
11/3/22	7.97			Yes
11/4/22	8			Yes
11/5/22	8.08			Yes
11/6/22	8.02			Yes
11/7/22	7.92			Yes
11/8/22	7.85			Yes
11/9/22	7.77	8.4		Yes
11/10/22	7.74			Yes
11/11/22	7.8			Yes
11/12/22	7.71			Yes
11/13/22	7.58			Yes
11/14/22	7.48			Yes
11/15/22	7.43			Yes
11/16/22	7.37	9.3		Yes
11/17/22	7.3			Yes
11/18/22	7.28			Yes
11/19/22	7.42			Yes
11/20/22	7.56			Yes
11/21/22	7.45			Yes
11/22/22	7.37			Yes
11/23/22	7.31	6.4		Yes
11/24/22	7.34			Yes
11/25/22	7.29			Yes
11/26/22	7.25			Yes
11/27/22	7.28			Yes
11/28/22	7.29			Yes
11/29/22	7.38			Yes
11/30/22	7.48	12.8		Yes

Entry Point

PWSID 4100359  
 System name Corbett Water District  
 Entry Point WTP-A Slow Sand Filter plant  
 Sample Period Nov-22

Number of excursionsn during this month **7**  
 (count the number of days when any WQP was less than minimum required)

Total excursion during the previous 5 months 2  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are culmulative)

For OHA use only

Minimum Water Quality Parameters as set by	pH 7	Alk 8	Alkanlinity
			Orthrophosphate
			Other

Print Name David Jacob  
 Signature David Jacob  
 Date 12/7/2022