

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
12/1/22	7.49			Yes
12/2/22	7.45			Yes
12/3/22	7.41			Yes
12/4/22	7.35			Yes
12/5/22	7.33			Yes
12/6/22	7.35			Yes
12/7/22	7.35	9.3		Yes
12/8/22	7.38			Yes
12/9/22	7.38			Yes
12/10/22	7.38			Yes
12/11/22	7.44			Yes
12/12/22	7.5			Yes
12/13/22	7.53			Yes
12/14/22	7.53	9.1		Yes
12/15/22	7.59			Yes
12/16/22	7.47			Yes
12/17/22	7.44			Yes
12/18/22	7.44			Yes
12/19/22	7.42			Yes
12/20/22	7.5			Yes
12/21/22	7.54	12.4		Yes
12/22/22	7.63			Yes
12/23/22	7.78			Yes
12/24/22	7.89			Yes
12/25/22	7.77			Yes
12/26/22	7.64			Yes
12/27/22	7.52			Yes
12/28/22	7.51	9.2		Yes
12/29/22	7.62			Yes
12/30/22	7.74			Yes
12/31/22	7.81			Yes

**Entry Point**

PWSID                      4100359

System name              Corbett Water District

Entry Point                WTP-A      Slow Sand Filter plant

Sample Period              Dec-22

Number of excursionsn during this month                      0  
(count the number of days when any WQP was  
less than minimum required)

Total excursion during the previous 5 months                      9

(Over 9 excursions in 6 months is a violation.  
Entry Point and Distribution excursions are  
culmulative

For OHA use only

Minimum Water Quality			
Parameters as set by			
pH	7		
Alk	8	Alkanlinity	
PO4		Orthrophosphate	
Other			

Print Name                                      David Jacob

Signature                                        David Jacob

Date    1/8/2023