

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
1/1/23	7.84			Yes
1/2/23	7.84			Yes
1/3/23	7.79			Yes
1/4/23	7.76	9.7		Yes
1/5/23	7.68			Yes
1/6/23	7.7			Yes
1/7/23	7.76			Yes
1/8/23	7.81			Yes
1/9/23	7.8			Yes
1/10/23	7.78			Yes
1/11/23	7.79	10.1		Yes
1/12/23	7.79			Yes
1/13/23	7.75			Yes
1/14/23	7.69			Yes
1/15/23	7.64			Yes
1/16/23	7.59			Yes
1/17/23	7.6			Yes
1/18/23	7.56	10.5		Yes
1/19/23	7.5			Yes
1/20/23	7.41			Yes
1/21/23	7.41			Yes
1/22/23	7.43			Yes
1/23/23	7.42			Yes
1/24/23	7.42			Yes
1/25/23	7.43	13.1		Yes
1/26/23	7.47			Yes
1/27/23	7.46			Yes
1/28/23	7.43			Yes
1/29/23	7.39			Yes
1/30/23	7.36			Yes
1/31/23	7.36			Yes

Entry Point

PWSID 4100359  
 System name Corbett Water District  
 Entry Point WTP-A Slow Sand Filter plant  
 Sample Period Jan-23

Number of excursionsn during this month 0  
 (count the number of days when any WQP was  
 less than minimum required)

Total excursion during the previous 5 months 7

(Over 9 excursions in 6 months is a violation.  
 Entry Point and Distribution excursions are  
 culmulative

For OHA use only

Minimum Water Quality Parameters as set by	pH	7	Alkanlinity
	Alk	8	Orthrophosphate
	PO4		
	Other		

Print Name David Jacob

Signature David Jacob

Date 2/5/2023