

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
2/1/23	7.42	14.2		Yes
2/2/23	7.44			Yes
2/3/23	7.45			Yes
2/4/23	7.44			Yes
2/5/23	7.37			Yes
2/6/23	7.35			Yes
2/7/23	7.32			Yes
2/8/23	7.3	12.1		Yes
2/9/23	7.32			Yes
2/10/23	7.35			Yes
2/11/23	7.38			Yes
2/12/23	7.32			Yes
2/13/23	7.28			Yes
2/14/23	7.28			Yes
2/15/23	7.29	9.5		Yes
2/16/23	7.3			Yes
2/17/23	7.3			Yes
2/18/23	7.5			Yes
2/19/23	7.35			Yes
2/20/23	7.24			Yes
2/21/23	7.14			Yes
2/22/23	7.07	10.4		Yes
2/23/23	7.04			Yes
2/24/23	7.04			Yes
2/25/23	7.13			Yes
2/26/23	7.19			Yes
2/27/23	7.18			Yes
2/28/23	7.3			Yes

Entry Point

PWSID 4100359
 System name Corbett Water District
 Entry Point WTP-A Slow Sand Filter plant
 Sample Period Feb-23

Number of excursionsn during this month 0
 (count the number of days when any WQP was less than minimum required)

Total excursion during the previous 5 months 7
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are culmulative)

For OHA use only

Minimum Water Quality Parameters as set by	pH 7	Alk 8	Alkanlinity
			Orthrophosphate
			Other

Print Name David Jacob
 Signature David Jacob
 Date 3/2/2023