

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
3/1/23	7.31	9.9		Yes
3/2/23	7.29			Yes
3/3/23	7.39			Yes
3/4/23	7.38			Yes
3/5/23	7.38			Yes
3/6/23	7.38			Yes
3/7/23	7.34			Yes
3/8/23	7.33	11.2		Yes
3/9/23	7.34			Yes
3/10/23	7.32			Yes
3/11/23	7.32			Yes
3/12/23	7.33			Yes
3/13/23	7.3			Yes
3/14/23	7.31			Yes
3/15/23	7.31	11		Yes
3/16/23	7.31			Yes
3/17/23	7.31			Yes
3/18/23	7.3			Yes
3/19/23	7.3			Yes
3/20/23	7.29			Yes
3/21/23	7.24			Yes
3/22/23	7.19	13.4		Yes
3/23/23	7.16			Yes
3/24/23	7.18			Yes
3/25/23	7.22			Yes
3/26/23	7.27			Yes
3/27/23	7.31			Yes
3/28/23	7.41	11.1		Yes
3/29/23	7.33			Yes
3/30/23	7.33			Yes
3/31/23	7.37			Yes

Entry Point

PWSID 4100359
 System name Corbett Water District
 Entry Point WTP-A Slow Sand Filter plant
 Sample Period Mar-23

Number of excursionsn during this month 0
 (count the number of days when any WQP was less than minimum required)

Total excursion during the previous 5 months 7
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are culmulative)

For OHA use only

Minimum Water Quality Parameters as set by	pH 7	Alk 8	Alkanlinity
			Orthrophosphate
			Other

Print Name David Jacob
 Signature David Jacob
 Date 4/2/2023