

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
4/1/23	7.4			Yes
4/2/23	7.44			Yes
4/3/23	7.31			Yes
4/4/23	7.27			Yes
4/5/23	7.26	14.4		Yes
4/6/23	7.3			Yes
4/7/23	7.36			Yes
4/8/23	7.5			Yes
4/9/23	7.45			Yes
4/10/23	7.42			Yes
4/11/23	7.42			Yes
4/12/23	7.41	16		Yes
4/13/23	7.42			Yes
4/14/23	7.41			Yes
4/15/23	7.36			Yes
4/16/23	7.31			Yes
4/17/23	7.25			Yes
4/18/23	7.22			Yes
4/19/23	7.22			Yes
4/20/23	7.2			Yes
4/21/23	7.22			Yes
4/22/23	7.29			Yes
4/23/23	7.15			Yes
4/24/23	7.11			Yes
4/25/23	7.1			Yes
4/26/23	7.1	15.2		Yes
4/27/23	7.13			Yes
4/28/23	7.18			Yes
4/29/23	7.15			Yes
4/30/23	7.13			Yes

Entry Point

PWSID 4100359
 System name Corbett Water District
 Entry Point WTP-A Slow Sand Filter plant
 Sample Period Apr-23

Number of excursionsn during this month 0
 (count the number of days when any WQP was
 less than minimum required)

Total excursion during the previous 5 months 7
 (Over 9 excursions in 6 months is a violation.
 Entry Point and Distribution excursions are
 culmulative)

For OHA use only

Minimum Water Quality Parameters as set by			
pH	7		
Alk	8	Alkanlinity	
PO4		Orthrophosphate	
Other			

Print Name David Jacob
 Signature _____
 Date 3-May _____