

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
5/1/23	7.13			Yes
5/2/23	7.2			Yes
5/3/23	7.24	10.4		Yes
5/4/23	7.36			Yes
5/5/23	7.34			Yes
5/6/23	7.41			Yes
5/7/23	7.49			Yes
5/8/23	7.55			Yes
5/9/23	7.57			Yes
5/10/23	7.57	14.8		Yes
5/11/23	7.44			Yes
5/12/23	7.38			Yes
5/13/23	7.49			Yes
5/14/23	7.52			Yes
5/15/23	7.36			Yes
5/16/23	7.3			Yes
5/17/23	7.23	11.5		Yes
5/18/23	7.13			Yes
5/19/23	7.02			Yes
5/20/23	7.02			Yes
5/21/23	7.06			Yes
5/22/23	7.25			Yes
5/23/23	7.46			Yes
5/24/23	7.38	13.1		Yes
5/25/23	7.34			Yes
5/26/23	7.28			Yes
5/27/23	7.2			Yes
5/28/23	7.14			Yes
5/29/23	7.11			Yes
5/30/23	7.14			Yes
5/31/23	7.27	10.1		Yes

Entry Point

PWSID 4100359
 System name Corbett Water District
 Entry Point WTP-A Slow Sand Filter plant
 Sample Period May-23

Number of excursionsn during this month 0
 (count the number of days when any WQP was less than minimum required)

Total excursion during the previous 5 months
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are culmulative)

For OHA use only

Minimum Water Quality Parameters as set by	pH	7	Alkanlinity
	Alk	8	Orthrophosphate
	PO4		
	Other		

Print Name David Jacob
 Signature David Jacob
 Date 6/4/2023