

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

| Day | pH | Alk | Phos other | Y/N |
|---------|------|------|------------|-----|
| 6/1/23 | 7.37 | | | Yes |
| 6/2/23 | 7.46 | | | Yes |
| 6/3/23 | 7.56 | | | Yes |
| 6/4/23 | 7.52 | | | Yes |
| 6/5/23 | 7.49 | | | Yes |
| 6/6/23 | 7.6 | | | Yes |
| 6/7/23 | 7.55 | 15 | | Yes |
| 6/8/23 | 7.1 | | | Yes |
| 6/9/23 | 7.11 | | | Yes |
| 6/10/23 | 7.11 | | | Yes |
| 6/11/23 | 7.1 | | | Yes |
| 6/12/23 | 7.08 | | | Yes |
| 6/13/23 | 7.04 | | | Yes |
| 6/14/23 | 7.15 | 13.2 | | Yes |
| 6/15/23 | 7.31 | | | Yes |
| 6/16/23 | 7.48 | | | Yes |
| 6/17/23 | 7.42 | | | Yes |
| 6/18/23 | 7.41 | | | Yes |
| 6/19/23 | 7.41 | | | Yes |
| 6/20/23 | 7.42 | | | Yes |
| 6/21/23 | 8.79 | 15 | | Yes |
| 6/22/23 | 8.57 | | | Yes |
| 6/23/23 | 8.48 | | | Yes |
| 6/24/23 | 8.63 | | | Yes |
| 6/25/23 | 8.56 | | | Yes |
| 6/26/23 | 8.53 | | | Yes |
| 6/27/23 | 8.54 | | | Yes |
| 6/28/23 | 8.59 | 16 | | Yes |
| 6/29/23 | 8.65 | | | Yes |
| 6/30/23 | 8.67 | | | Yes |

Entry Point

PWSID 4100359
 System name Corbett Water District
 Entry Point WTP-A Slow Sand Filter plant
 Sample Period Jun-23

Number of excursionsn during this month 0
 (count the number of days when any WQP was
 less than minimum required)

Total excursion during the previous 5 months 0
 (Over 9 excursions in 6 months is a violation.
 Entry Point and Distribution excursions are
 culmulative)

For OHA use only

| | | | |
|-----------------------|---|-----------------|--|
| Minimum Water Quality | | | |
| Parameters as set by | | | |
| pH | 7 | | |
| Alk | 8 | Alkanlinity | |
| PO4 | | Orthrophosphate | |
| Other | | | |

Print Name David Jacob
 Signature David Jacob
 Date 7/5/2023