

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
7/1/23	8.67			Yes
7/2/23	8.66			Yes
7/3/23	8.63			Yes
7/4/23	8.62			Yes
7/5/23	8.63	16.7		Yes
7/6/23	8.66			Yes
7/7/23	8.67			Yes
7/8/23	8.71			Yes
7/9/23	8.74			Yes
7/10/23	8.74			Yes
7/11/23	8.77			Yes
7/12/23	8.72	19.7		Yes
7/13/23	8.55			Yes
7/14/23	8.48			Yes
7/15/23	8.48			Yes
7/16/23	8.46			Yes
7/17/23	8.46			Yes
7/18/23	8.47			Yes
7/19/23	8.45	20		Yes
7/20/23	8.44			Yes
7/21/23	8.49			Yes
7/22/23	8.51			Yes
7/23/23	8.56			Yes
7/24/23	8.4			Yes
7/25/23	8.17			Yes
7/26/23	8.09	20.1		Yes
7/27/23	8.07			Yes
7/28/23	8.17			Yes
7/29/23	8.46			Yes
7/30/23	8.55			Yes
7/31/23	8.59			Yes

Entry Point

PWSID 4100359
 System name Corbett Water District
 Entry Point WTP-A Slow Sand Filter plant
 Sample Period Jul-23

Number of excursionsn during this month 2
 (count the number of days when any WQP was
 less than minimum required)

Total excursion during the previous 5 months
 (Over 9 excursions in 6 months is a violation.
 Entry Point and Distribution excursions are
 culmulative)

For OHA use only

Minimum Water Quality			
Parameters as set by			
pH	7		
Alk	8	Alkanlinity	
PO4		Orthrophosphate	
Other			

Print Name David Jacob
 Signature David Jacob
 Date 8/2/2023