

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
8/1/23	7.95	17.7		Yes
8/2/23	7.75		Yes	
8/3/23	7.76		Yes	
8/4/23	7.73		Yes	
8/5/23	7.73		Yes	
8/6/23	7.69		Yes	
8/7/23	7.9		Yes	
8/8/23	7.92	22		Yes
8/9/23	7.93		Yes	
8/10/23	7.93		Yes	
8/11/23	7.95		Yes	
8/12/23	7.97		Yes	
8/13/23	7.94		Yes	
8/14/23	7.99		Yes	
8/15/23	7.9	23.1		Yes
8/16/23	7.88		Yes	
8/17/23	7.83		Yes	
8/18/23	8.01		Yes	
8/19/23	8.01		Yes	
8/20/23	8.03		Yes	
8/21/23	8.02		Yes	
8/22/23	8.01	22.5		Yes
8/23/23	7.99		Yes	
8/24/23	8.02		Yes	
8/25/23	8		Yes	
8/26/23	7.95		Yes	
8/27/23	7.87		Yes	
8/28/23	8.1		Yes	
8/29/23	7.9	Yes		
8/30/23	8.39	Yes		
8/31/23	8.05	Yes		

Entry Point

PWSID 4100359
 System name Corbett Water District
 Entry Point WTP-A Slow Sand Filter plant
 Sample Period Aug-23

Number of excursionsn during this month 0
 (count the number of days when any WQP was
 less than minimum required)

Total excursion during the previous 5 months
 (Over 9 excursions in 6 months is a violation.
 Entry Point and Distribution excursions are
 culmulative)

For OHA use only

Minimum Water Quality Parameters as set by			
pH	7		
Alk	8	Alkanlinity	
PO4		Orthrophosphate	
Other			

Print Name David Jacob
 Signature David Jacob
 Date 9/3/2023