

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
9/1/23	8.86			Yes
9/2/23	8.9			Yes
9/3/23	8.87			Yes
9/4/23	8.84			Yes
9/5/23	8.83			Yes
9/6/23	8.85	23.6		Yes
9/7/23	8.95			Yes
9/8/23	8.96			Yes
9/9/23	8.89			Yes
9/10/23	8.8			Yes
9/11/23	8.72			Yes
9/12/23	8.66			Yes
9/13/23	8.52	20.7		Yes
9/14/23	8.39			Yes
9/15/23	8.33			Yes
9/16/23	8.32			Yes
9/17/23	8.32			Yes
9/18/23	8.32			Yes
9/19/23	8.32			Yes
9/20/23	8.33	14		Yes
9/21/23	8.35			Yes
9/22/23	8.37			Yes
9/23/23	8.4			Yes
9/24/23	8.45			Yes
9/25/23	8.47			Yes
9/26/23	8.49			Yes
9/27/23	8.46	21.5		Yes
9/28/23	8.48			Yes
9/29/23	8.53			Yes
9/30/23	8.56			Yes

Entry Point

PWSID 4100359  
 System name Corbett Water District  
 Entry Point WTP-A Slow Sand Filter plant  
 Sample Period Sep-23  
 Number of excursionsn during this month 0  
 (count the number of days when any WQP was less than minimum required)  
 Total excursion during the previous 5 months  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are culmulative)  
 For OHA use only

Minimum Water Quality Parameters as set by	pH 7	Alk 8	Alkanlinity
			Orthrophosphate
			Other

Print Name David Jacob  
 Signature David Jacob  
 Date 10/2/2023