

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
10/1/23	7.68			Yes
10/2/23	8.94			Yes
10/3/23	8.94			Yes
10/4/23	8.28	21.7		Yes
10/5/23	8.28			Yes
10/6/23	8.25			Yes
10/7/23	8.12			Yes
10/8/23	8.06			Yes
10/9/23	8.34			Yes
10/10/23	8.37			Yes
10/11/23	8.37			Yes
10/12/23	8.39	21.7		Yes
10/13/23	8.39			Yes
10/14/23	8.39			Yes
10/15/23	8.39			Yes
10/16/23	8.38			Yes
10/17/23	8.38			Yes
10/18/23	8.38	17.1		Yes
10/19/23	8.38			Yes
10/20/23	8.30			Yes
10/21/23	8.28			Yes
10/22/23	8.36			Yes
10/23/23	8.46			Yes
10/24/23	8.55			Yes
10/25/23	8.59	21.1		Yes
10/26/23	8.86			Yes
10/27/23	8.52			Yes
10/28/23	8.65			Yes
10/29/23	8.45			Yes
10/30/23	8.86			Yes
10/31/23	8.52			Yes

Entry Point

PWSID 4100359  
 System name Corbett Water District  
 Entry Point WTP-A Slow Sand Filter plant  
 Sample Period Oct-23

Number of excursionsn during this month 0  
 (count the number of days when any WQP was  
 less than minimum required)

Total excursion during the previous 5 months  
 (Over 9 excursions in 6 months is a violation.  
 Entry Point and Distribution excursions are  
 culmulative)

For OHA use only

Minimum Water Quality Parameters as set by		
pH	7	
Alk	8	Alkanlinity
PO4		Orthrophosphate
Other		

Print Name David Jacob  
 Signature David Jacob  
 Date 11/7/2023