

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
11/1/23	8.36			Yes
11/2/23	8.3			Yes
11/3/23	7.74			Yes
11/4/23	7.46			Yes
11/5/23	7.45			Yes
11/6/23	7.8			Yes
11/7/23	8.11			Yes
11/8/23	7.72	14.0		Yes
11/9/23	7.74			Yes
11/10/23	7.76			Yes
11/11/23	7.75			Yes
11/12/23	7.72			Yes
11/13/23	7.75			Yes
11/14/23	7.72			Yes
11/15/23	7.56	14.0		Yes
11/16/23	7.57			Yes
11/17/23	7.55			Yes
11/18/23	7.55			Yes
11/19/23	7.5			Yes
11/20/23	7.45			Yes
11/21/23	7.42			Yes
11/22/23	7.42	9.0		Yes
11/23/23	7.41			Yes
11/24/23	7.42			Yes
11/25/23	7.44			Yes
11/26/23	7.5			Yes
11/27/23	7.5			Yes
11/28/23	7.48			Yes
11/29/23	7.5	9.0		Yes
11/30/23	7.51			Yes

Entry Point

PWSID 4100359
 System name Corbett Water District
 Entry Point WTP-A Slow Sand Filter plant
 Sample Period Nov-23

Number of excursionsn during this month 0
 (count the number of days when any WQP was
 less than minimum required)

Total excursion during the previous 5 months 0
 (Over 9 excursions in 6 months is a violation.
 Entry Point and Distribution excursions are
 culmulative)

For OHA use only

Minimum Water Quality Parameters as set by	pH 7	Alk 8	Alkanlinity
			Orthrophosphate
			Other

Print Name David Jacob
 Signature David Jacob
 Date 12/2/2023