

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
12/1/23	8.21			Yes
12/2/23	8.42			Yes
12/3/23	8.69			Yes
12/4/23	8.87			Yes
12/5/23	9.01			Yes
12/6/23	9.11	14.6		Yes
12/7/23	8.92			Yes
12/8/23	9.19			Yes
12/9/23	9.16			Yes
12/10/23	9.05			Yes
12/11/23	9.05			Yes
12/12/23	8.98			Yes
12/13/23	8.96	14		Yes
12/14/23	8.95			Yes
12/15/23	8.93			Yes
12/16/23	8.84			Yes
12/17/23	8.78			Yes
12/18/23	8.72			Yes
12/19/23	8.69			Yes
12/20/23	8.69	14.7		Yes
12/21/23	8.69			Yes
12/22/23	8.67			Yes
12/23/23	8.64			Yes
12/24/23	8.6			Yes
12/25/23	8.56			Yes
12/26/23	8.57			Yes
12/27/23	8.54			Yes
12/28/23	8.55			Yes
12/29/23	8.52			Yes
12/30/23	8.52			Yes
12/31/23	8.51			Yes

Entry Point

PWSID 4100359
 System name Corbett Water District
 Entry Point WTP-A Slow Sand Filter plant
 Sample Period Dec-23

Number of excursionsn during this month 0
 (count the number of days when any WQP was
 less than minimum required)

Total excursion during the previous 5 months
 (Over 9 excursions in 6 months is a violation.
 Entry Point and Distribution excursions are
 culmulative)

For OHA use only

Minimum Water Quality			
Parameters as set by			
pH	7		
Alk	8	Alkanlity	
PO4		Orthrophosphate	
Other			

Print Name David Jacob
 Signature _____
 Date _____