

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
1/1/24	7.96			Yes
1/2/24	8			Yes
1/3/24	7.99	15.1		Yes
1/4/24	8			Yes
1/5/24	7.92			Yes
1/6/24	7.9			Yes
1/7/24	7.9			Yes
1/8/24	7.91			Yes
1/9/24	7.79			Yes
1/10/24	7.76	13.9		Yes
1/11/24	7.95			Yes
1/12/24	8.32			Yes
1/13/24	8.28			Yes
1/14/24	7.73			Yes
1/15/24	7.77			Yes
1/16/24	7.89	14.5		Yes
1/17/24	7.66			Yes
1/18/24	7.78			Yes
1/19/24	7.86	17.2		Yes
1/20/24	7.81			Yes
1/21/24	7.78			Yes
1/22/24	7.74			Yes
1/23/24	8.96			Yes
1/24/24	7.76			Yes
1/25/24	7.75			Yes
1/26/24	7.73			Yes
1/27/24	7.76			Yes
1/28/24	7.76			Yes
1/29/24	7.82	12.4		Yes
1/30/24	7.84			Yes
1/31/24	7.77			Yes

Entry Point

PWSID 4100359  
 System name Corbett Water District  
 Entry Point WTP-A Slow Sand Filter plant  
 Sample Period Jan-24  
 Number of excursionsn during this month 0  
 (count the number of days when any WQP was  
 less than minimum required)  
 Total excursion during the previous 5 months 0  
 (Over 9 excursions in 6 months is a violation.  
 Entry Point and Distribution excursions are  
 culmulative

For OHA use only  
 Minimum Water Quality  
 Parameters as set by  
 pH 7  
 Alk 8 Alkanlinity  
 PO4 Orthrophosphate  
 Other

Print Name David Jacob  
 Signature David Jacob  
 Date 2/2/2024