

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
2/1/24	8.36	13.7		Yes
2/2/24	8.35			Yes
2/3/24	8.32			Yes
2/4/24	8.29			Yes
2/5/24	8.27			Yes
2/6/24	8.25			Yes
2/7/24	8.25	15.3		Yes
2/8/24	8.24			Yes
2/9/24	8.23			Yes
2/10/24	8.23			Yes
2/11/24	8.24			Yes
2/12/24	8.24			Yes
2/13/24	8.22			Yes
2/14/24	8.22	14.1		Yes
2/15/24	8.24			Yes
2/16/24	8.26			Yes
2/17/24	8.32			Yes
2/18/24	8.32			Yes
2/19/24	8.34			Yes
2/20/24	8.34			Yes
2/21/24	8.37	14.7		Yes
2/22/24	8.38			Yes
2/23/24	8.39			Yes
2/24/24	8.41			Yes
2/25/24	8.42			Yes
2/26/24	8.39			Yes
2/27/24	8.39			Yes
2/28/24	8.41	14.2		Yes
2/29/24	8.42			Yes

Entry Point

PWSID 4100359
 System name Corbett Water District
 Entry Point WTP-A Slow Sand Filter plant
 Sample Period Feb-24

Number of excursionsn during this month 0
 (count the number of days when any WQP was
 less than minimum required)

Total excursion during the previous 5 months 0
 (Over 9 excursions in 6 months is a violation.
 Entry Point and Distribution excursions are
 culmulative)

For OHA use only

Minimum Water Quality			
Parameters as set by			
pH	7		
Alk	8	Alkanlinity	
PO4		Orthrophosphate	
Other			

Print Name David Jacob

Signature

Date

3/2/2024