

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
3/1/24	7.77			Yes
3/2/24	7.88			Yes
3/3/24	7.89			Yes
3/4/24	7.9			Yes
3/5/24	7.98			Yes
3/6/24	7.93	12.3		Yes
3/7/24	7.87			Yes
3/8/24	7.82			Yes
3/9/24	7.89			Yes
3/10/24	7.8			Yes
3/11/24	7.82			Yes
3/12/24	7.8			Yes
3/13/24	7.87	13.4		Yes
3/14/24	7.76			Yes
3/15/24	7.84			Yes
3/16/24	7.76			Yes
3/17/24	7.8			Yes
3/18/24	7.85			Yes
3/19/24	7.68			Yes
3/20/24	7.75	12.9		Yes
3/21/24	8.04			Yes
3/22/24	8.02			Yes
3/23/24	8.01			Yes
3/24/24	8.08			Yes
3/25/24	8.05			Yes
3/26/24	7.86	12		Yes
3/27/24	7.91			Yes
3/28/24	7.75			Yes
3/29/24	7.83			Yes
3/30/24	7.79			Yes
3/31/24	7.72			Yes

Entry Point

PWSID 4100359  
 System name Corbett Water District  
 Entry Point WTP-A Slow Sand Filter plant  
 Sample Period Mar-24  
 Number of excursionsn during this month 0  
 (count the number of days when any WQP was less than minimum required)  
 Total excursion during the previous 5 months 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are culmulative)  
 For OHA use only  
 Minimum Water Quality Parameters as set by  
 pH 7  
 Alk 8 Alkanlinity  
 PO4 Orthrophosphate  
 Other

Print Name David Jacob  
 Signature David Jacob  
 Date 4/2/2024