

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
4/1/24	8.39			Yes
4/2/24	8.39			Yes
4/3/24	8.37	12.7		Yes
4/4/24	8.34			Yes
4/5/24	8.35			Yes
4/6/24	8.34			Yes
4/7/24	8.34			Yes
4/8/24	8.37			Yes
4/9/24	8.4			Yes
4/10/24	8.4	8		Yes
4/11/24	8.4			Yes
4/12/24	8.31			Yes
4/13/24	8.21			Yes
4/14/24	8.22			Yes
4/15/24	8.22			Yes
4/16/24	8.21			Yes
4/17/24	8.19	10.4		Yes
4/18/24	8.2			Yes
4/19/24	8.16			Yes
4/20/24	8.11			Yes
4/21/24	8.06			Yes
4/22/24	8.03			Yes
4/23/24	8.02			Yes
4/24/24	8	11.5		Yes
4/25/24	8			Yes
4/26/24	8.01			Yes
4/27/24	8.07			Yes
4/28/24	8.13			Yes
4/29/24	8.19			Yes
4/30/24	8.19			Yes

Entry Point

PWSID 4100359
 System name Corbett Water District
 Entry Point WTP-A Slow Sand Filter plant
 Sample Period Apr-24

Number of excursionsn during this month 0
 (count the number of days when any WQP was less than minimum required)

Total excursion during the previous 5 months 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are culmulative)

For OHA use only

Minimum Water Quality Parameters as set by	pH 7	Alk 8	Alkanlinity
			Orthrophosphate
			Other

Slow Sand/

Print Name David Jacob
 Signature David Jacob
 Date 5/2/2024