

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
5/1/24	7.42	12.1		Yes
5/2/24	7.41			Yes
5/3/24	7.42			Yes
5/4/24	7.4			Yes
5/5/24	7.34			Yes
5/6/24	7.25			Yes
5/7/24	7.19			Yes
5/8/24	7.15	14		Yes
5/9/24	7.36			Yes
5/10/24	7.35			Yes
5/11/24	7.35			Yes
5/12/24	7.31			Yes
5/13/24	7.37			Yes
5/14/24	7.33			Yes
5/15/24	7.34	14.1		Yes
5/16/24	7.34			Yes
5/17/24	7.32			Yes
5/18/24	7.34			Yes
5/19/24	7.37			Yes
5/20/24	7.41			Yes
5/21/24	7.43			Yes
5/22/24	7.44	14.8		Yes
5/23/24	7.41			Yes
5/24/24	7.33			Yes
5/25/24	7.3			Yes
5/26/24	7.28			Yes
5/27/24	7.24			Yes
5/28/24	7.22			Yes
5/29/24	7.23	13.2		Yes
5/30/24	7.25			Yes
5/31/24	7.26			Yes

Entry Point

PWSID 4100359  
 System name Corbett Water District  
 Entry Point WTP-A Slow Sand Filter plant  
 Sample Period May-24

Number of excursionsn during this month 0  
 (count the number of days when any WQP was less than minimum required)

Total excursion during the previous 5 months 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are culmulative)

For OHA use only

Minimum Water Quality			
Parameters as set by			
pH	7		
Alk	8	Alkanlinity	
PO4		Orthrophosphate	
Other			

Print Name David Jacob  
 Signature David Jacob  
 Date 6/2/2024