

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

| Day     | pH   | Alk  | Phos other | Y/N |
|---------|------|------|------------|-----|
| 6/1/24  | 7.8  |      |            | Yes |
| 6/2/24  | 7.76 |      |            | Yes |
| 6/3/24  | 8.82 |      |            | Yes |
| 6/4/24  | 8.52 |      |            | Yes |
| 6/5/24  | 8.37 |      |            | Yes |
| 6/6/24  | 8    |      |            | Yes |
| 6/7/24  | 8    |      |            | Yes |
| 6/8/24  | 7.65 |      |            | Yes |
| 6/9/24  | 7.53 |      |            | Yes |
| 6/10/24 | 7.5  |      |            | Yes |
| 6/11/24 | 7.52 | 11.4 |            | Yes |
| 6/12/24 | 7.69 |      |            | Yes |
| 6/13/24 | 8.62 |      |            | Yes |
| 6/14/24 | 7.43 |      |            | Yes |
| 6/15/24 | 7.35 |      |            | Yes |
| 6/16/24 | 7.38 |      |            | Yes |
| 6/17/24 | 7.44 |      |            | Yes |
| 6/18/24 | 7.48 |      |            | Yes |
| 6/19/24 | 7.53 | 12.9 |            | Yes |
| 6/20/24 | 7.5  |      |            | Yes |
| 6/21/24 | 7.5  |      |            | Yes |
| 6/22/24 | 7.5  |      |            | Yes |
| 6/23/24 | 7.53 |      |            | Yes |
| 6/24/24 | 7.95 |      |            | Yes |
| 6/25/24 | 7.66 |      |            | Yes |
| 6/26/24 | 7.68 | 13.2 |            | Yes |
| 6/27/24 | 7.78 |      |            | Yes |
| 6/28/24 | 7.69 |      |            | Yes |
| 6/29/24 | 7.64 |      |            | Yes |
| 6/30/24 | 7.47 |      |            | Yes |

Entry Point

PWSID 4100359  
 System name Corbett Water District  
 Entry Point WTP-A Slow Sand Filter plant  
 Sample Period Jun-24

Number of excursionsn during this month 0  
 (count the number of days when any WQP was  
 less than minimum required)

Total excursion during the previous 5 months 0  
 (Over 9 excursions in 6 months is a violation.  
 Entry Point and Distribution excursions are  
 culmulative)

For OHA use only

|                       |   |                 |  |
|-----------------------|---|-----------------|--|
| Minimum Water Quality |   |                 |  |
| Parameters as set by  |   |                 |  |
| pH                    | 7 |                 |  |
| Alk                   | 8 | Alkanlinity     |  |
| PO4                   |   | Orthrophosphate |  |
| Other                 |   |                 |  |

Print Name David Jacob

Signature \_\_\_\_\_

Date \_\_\_\_\_