

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
7/1/24	8.16			Yes
7/2/24	8.17			Yes
7/3/24	8.11	13.4		Yes
7/4/24	8.06			Yes
7/5/24	8.04			Yes
7/6/24	8			Yes
7/7/24	7.98			Yes
7/8/24	7.96			Yes
7/9/24	7.95			Yes
7/10/24	7.91	17.2		Yes
7/11/24	7.87			Yes
7/12/24	7.86			Yes
7/13/24	7.87			Yes
7/14/24	7.88			Yes
7/15/24	8.03			Yes
7/16/24	8.14			Yes
7/17/24	8.2	15.1		Yes
7/18/24	7.93			Yes
7/19/24	8.31			Yes
7/20/24	8.33			Yes
7/21/24	8.33			Yes
7/22/24	8.35			Yes
7/23/24	8.43			Yes
7/24/24	8.38	17.1		Yes
7/25/24	8.38			Yes
7/26/24	8.44			Yes
7/27/24	8.43			Yes
7/28/24	8.47			Yes
7/29/24	8.48			Yes
7/30/24	8.49			Yes
7/31/24	8.54	18.4		Yes

Entry Point

PWSID 4100359
 System name Corbett Water District
 Entry Point WTP-A Slow Sand Filter plant
 Sample Period Jul-24

Number of excursionsn during this month 0
 (count the number of days when any WQP was
 less than minimum required)

Total excursion during the previous 5 months 0
 (Over 9 excursions in 6 months is a violation.
 Entry Point and Distribution excursions are
 culmulative)

For OHA use only

Minimum Water Quality			
Parameters as set by			
pH	7		
Alk	8	Alkanlinity	
PO4		Orthrophosphate	
Other			

Print Name David Jacob

Signature David Jacob

Date 8/2/2024