

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
8/1/24	8.6			Yes
8/2/24	8.54			Yes
8/3/24	8.54			Yes
8/4/24	8.57			Yes
8/5/24	8.56			Yes
8/6/24	8.56			Yes
8/7/24	8.54	18.7		Yes
8/8/24	8.58			Yes
8/9/24	8.61			Yes
8/10/24	8.62			Yes
8/11/24	8.6			Yes
8/12/24	8.56			Yes
8/13/24	8.55			Yes
8/14/24	8.55	21.9		Yes
8/15/24	8.57			Yes
8/16/24	8.62			Yes
8/17/24	8.5			Yes
8/18/24	8.69			Yes
8/19/24	8.5			Yes
8/20/24	8.67			Yes
8/21/24	8.67	21.8		Yes
8/22/24	8.71			Yes
8/23/24	8.72			Yes
8/24/24	8.67			Yes
8/25/24	8.68			Yes
8/26/24	8.63			Yes
8/27/24	8.54			Yes
8/28/24	8.45	25.3		Yes
8/29/24	8.47			Yes
8/30/24	8.52			Yes
8/31/24	8.52			Yes

Entry Point

PWSID 4100359
 System name Corbett Water District
 Entry Point WTP-A Slow Sand Filter plant
 Sample Period Aug-24

Number of excursionsn during this month 0
 (count the number of days when any WQP was less than minimum required)

Total excursion during the previous 5 months 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are culmulative)

For OHA use only

Minimum Water Quality			
Parameters as set by			
pH	7		
Alk	8	Alkanlinity	
PO4		Orthrophosphate	
Other			

Print Name David Jacob
 Signature David Jacob
 Date 9/3/2023