

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
9/1/24	7.71			Yes
9/2/24	7.64			Yes
9/3/24	7.67			Yes
9/4/24	7.69			Yes
9/5/24	8.25	22.8		Yes
9/6/24	8.21			Yes
9/7/24	7.84			Yes
9/8/24	7.87			Yes
9/9/24	7.84			Yes
9/10/24	7.57			Yes
9/11/24	7.66			Yes
9/12/24	7.79	21.9		Yes
9/13/24	8.09			Yes
9/14/24	8.11			Yes
9/15/24	8.07			Yes
9/16/24	8.09			Yes
9/17/24	8.07			Yes
9/18/24	7.51			Yes
9/19/24	7.46	24.7		Yes
9/20/24	7.43			Yes
9/21/24	7.48			Yes
9/22/24	7.47			Yes
9/23/24	7.55			Yes
9/24/24	7.45			Yes
9/25/24	7.41	23.7		Yes
9/26/24	7.55			Yes
9/27/24	7.62			Yes
9/28/24	7.66			Yes
9/29/24	7.61			Yes
9/30/24	7.62			Yes

Entry Point

PWSID 4100359
 System name Corbett Water District
 Entry Point WTP-A Slow Sand Filter plant
 Sample Period Sep-24

Number of excursionsn during this month 0
 (count the number of days when any WQP was less than minimum required)

Total excursion during the previous 5 months 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are culmulative)

For OHA use only

Minimum Water Quality Parameters as set by			
pH	7		
Alk	8	Alkanlinity	
PO4		Orthrophosphate	
Other			

Print Name David Jacob
 Signature David Jacob
 Date 10/5/2024