

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
10/1/24	7.63			Yes
10/2/24	7.53	23.7		Yes
10/3/24	7.56			Yes
10/4/24	7.59			Yes
10/5/24	7.64			Yes
10/6/24	7.69			Yes
10/7/24	7.69			Yes
10/8/24	7.55			Yes
10/9/24	7.53	27.3		Yes
10/10/24	7.56			Yes
10/11/24	7.60			Yes
10/12/24	7.58			Yes
10/13/24	7.54			Yes
10/14/24	7.53			Yes
10/15/24	7.57			Yes
10/16/24	7.67	26.1		Yes
10/17/24	7.67			Yes
10/18/24	7.69			Yes
10/19/24	7.73			Yes
10/20/24	7.73			Yes
10/21/24	7.72			Yes
10/22/24	7.95			Yes
10/23/24	8.09	23.3		Yes
10/24/24	8.08			Yes
10/25/24	8.10			Yes
10/26/24	8.12			Yes
10/27/24	7.99			Yes
10/28/24	8.05			Yes
10/29/24	8.23			Yes
10/30/24	8.41	21.3		Yes
10/31/24	8.44			Yes

Entry Point

PWSID 4100359  
 System name Corbett Water District  
 Entry Point WTP-A Slow Sand Filter plant  
 Sample Period Oct-24

Number of excursionsn during this month 0  
 (count the number of days when any WQP was less than minimum required)

Total excursion during the previous 5 months 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are culmulative)

For OHA use only

Minimum Water Quality Parameters as set by	pH	7	Alkanlinity
	Alk	8	Orthrophosphate
	PO4		
	Other		

Print Name David Jacob  
 Signature David Jacob  
 Date 11/2/2024