

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
11/1/24	8.46			Yes
11/2/24	8.43			Yes
11/3/24	8.35			Yes
11/4/24	8.35			Yes
11/5/24	8.23			Yes
11/6/24	8.28	14.8		Yes
11/7/24	8.28			Yes
11/8/24	8.31			Yes
11/9/24	8.26			Yes
11/10/24	8.15			Yes
11/11/24	8.14			Yes
11/12/24	8.1			Yes
11/13/24	8.1	20.6		Yes
11/14/24	8.05			Yes
11/15/24	8.09			Yes
11/16/24	8.08			Yes
11/17/24	8.07			Yes
11/18/24	8.02			Yes
11/19/24	8.03			Yes
11/20/24	8.07	15.5		Yes
11/21/24	8.09			Yes
11/22/24	8.09			Yes
11/23/24	8.09			Yes
11/24/24	8.08			Yes
11/25/24	8.1			Yes
11/26/24	8.1			Yes
11/27/24	8.09	13.9		Yes
11/28/24	8.06			Yes
11/29/24	8.08			Yes
11/30/24	8.02			Yes

Entry Point

PWSID 4100359  
 System name Corbett Water District  
 Entry Point WTP-A Slow Sand Filter plant  
 Sample Period Nov-24

Number of excursionsn during this month 0  
 (count the number of days when any WQP was less than minimum required)

Total excursion during the previous 5 months 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are culmulative)

For OHA use only

Minimum Water Quality Parameters as set by			
pH	7		
Alk	8	Alkanlinity	
PO4		Orthrophosphate	
Other			

Print Name David Jacob  
 Signature David Jacob  
 Date 12/2/2024