

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
12/1/24	8.76			Yes
12/2/24	8.75			Yes
12/3/24	8.74			Yes
12/4/24	8.72	14.2		Yes
12/5/24	8.74			Yes
12/6/24	8.74			Yes
12/7/24	8.73			Yes
12/8/24	8.67			Yes
12/9/24	8.63			Yes
12/10/24	8.57			Yes
12/11/24	8.55	15		Yes
12/12/24	8.5			Yes
12/13/24	8.48			Yes
12/14/24	8.45			Yes
12/15/24	8.46			Yes
12/16/24	8.48			Yes
12/17/24	8.46			Yes
12/18/24	8.47	12.1		Yes
12/19/24	8.49			Yes
12/20/24	8.48			Yes
12/21/24	8.43			Yes
12/22/24	8.42			Yes
12/23/24	8.37			Yes
12/24/24	8.36	12.5		Yes
12/25/24	8.36			Yes
12/26/24	0			No
12/27/24	0			No
12/28/24	8.36			Yes
12/29/24	8.46			Yes
12/30/24	8.52			Yes
12/31/24	8.64	16.5		Yes

Entry Point

PWSID 4100359
 System name Corbett Water District
 Entry Point WTP-A Slow Sand Filter plant
 Sample Period Dec-24

Number of excursionsn during this month 2
 (count the number of days when any WQP was less than minimum required)

Total excursion during the previous 5 months 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are culmulative)

For OHA use only

Minimum Water Quality			
Parameters as set by			
pH	7		
Alk	8	Alkanlinity	
PO4		Orthrophosphate	
Other			

Print Name David Jacob
 Signature David Jacob
 Date 1/2/2025