

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
1/1/25	7.76			Yes
1/2/25	7.7			Yes
1/3/25	7.7			Yes
1/4/25	7.47			Yes
1/5/25	7.48			Yes
1/6/25	7.75			Yes
1/7/25	7.89			Yes
1/8/25	8.23	12.5		Yes
1/9/25	8			Yes
1/10/25	8.03			Yes
1/11/25	8.1			Yes
1/12/25	8.04			Yes
1/13/25	8.02			Yes
1/14/25	8.02			Yes
1/15/25	8.02	11.4		Yes
1/16/25	7.99			Yes
1/17/25	7.98			Yes
1/18/25	7.98			Yes
1/19/25	7.98			Yes
1/20/25	7.88			Yes
1/21/25	7.82			Yes
1/22/25	7.88	14.7		Yes
1/23/25	7.93			Yes
1/24/25	7.84			Yes
1/25/25	7.95			Yes
1/26/25	7.97			Yes
1/27/25	8.03			Yes
1/28/25	7.85			Yes
1/29/25	7.86	12.3		Yes
1/30/25	7.93			Yes
1/31/25	7.95			Yes

Entry Point

PWSID 4100359

System name Corbett Water District

Entry Point WTP-A Slow Sand Filter plant

Sample Period Jan-25

Number of excursionsn during this month 0
(count the number of days when any WQP was less than minimum required)

Total excursion during the previous 5 months 0

(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are culmulative)

For OHA use only

Minimum Water Quality

Parameters as set by

pH 7

Alk 8 Alkanlinity

PO4 Orthrophosphate

Other

Print Name Alivia Pence

Signature *Alivia Pence*

Date 2/3/2025