

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrosion Control

Day	pH	Alk	Phos other	Y/N
2/1/25	8.02			Yes
2/2/25	8.07			Yes
2/3/25	8.09			Yes
2/4/25	8.19			Yes
2/5/25	8.13	17.6		Yes
2/6/25	8.05			Yes
2/7/25	8.01	14.5		Yes
2/8/25	8.02			Yes
2/9/25	8.01			Yes
2/10/25	7.97			Yes
2/11/25	7.95			Yes
2/12/25	7.96	16.5		Yes
2/13/25	8.01			Yes
2/14/25	7.91	16.4		Yes
2/15/25	8.01			Yes
2/16/25	7.85			Yes
2/17/25	7.85			Yes
2/18/25	7.89			Yes
2/19/25	8.01	14.7		Yes
2/20/25	8.04			Yes
2/21/25	8.08	13.6		Yes
2/22/25	8.2			Yes
2/23/25	8.22			Yes
2/24/25	8.24			Yes
2/25/25	8.13			Yes
2/26/25	8.25	11.3		Yes
2/27/25	8.33			Yes
2/28/25	8.36	11.7		Yes

Entry Point

PWSID 4100359
 System name Corbett Water District
 Entry Point WTP-A Slow Sand Filter plant
 Sample Period Feb-25

Number of excursions during this month 0
 (count the number of days when any WQP was less than minimum required)

Total excursion during the previous 5 months 0
 (Over 9 excursions in 6 months is a violation.
 Entry Point and Distribution excursions are culmulative)

For OHA use only

Minimum Water Quality Parameters as set by			
pH	7		
Alk	8	Alkalinity	
PO4		Orthophosphate	
Other			

Print Name Alivia Pence

Signature Alivia Pence

Date 3/3/2025