

Water Quality Parameter Monitoring Form


Lead and Copper Rule Corrosion Control

Day	pH	Alk	Phos other	Y/N
2/1/25				No
2/2/25				No
2/3/25				No
2/4/25				No
2/5/25		17.6		No
2/6/25				No
2/7/25		14.5		No
2/8/25				No
2/9/25				No
2/10/25				No
2/11/25				No
2/12/25		16.5		No
2/13/25				No
2/14/25		16.4		No
2/15/25				No
2/16/25				No
2/17/25				No
2/18/25				No
2/19/25		14.7		No
2/20/25				No
2/21/25		13.6		No
2/22/25				No
2/23/25				No
2/24/25				No
2/25/25				No
2/26/25		11.3		No
2/27/25				No
2/28/25		11.7		No

Entry Point

PWSID 4100359
System name Corbett Water District
Entry Point WTP-A Slow Sand Filter plant
Sample Period Feb-25

Number of excursions during this month 28
(count the number of days when any WQP was less than minimum required)

 Total excursion during the previous 5 months 0

(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are culmulative

For OHA use only

Minimum Water Quality Parameters as set by			
pH	7		
Alk	8	Alkalinity	
PO4		Orthophosphate	
Other			

Print Name Alivia Pence

Signature Alivia Pence

Date 3/3/2025