

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
3/1/25	8.51			Yes
3/2/25	8.51			Yes
3/3/25	8.48			Yes
3/4/25	8.46			Yes
3/5/25	8.44	11.3		Yes
3/6/25	8.38			Yes
3/7/25	8.21	11.7		Yes
3/8/25	8.18			Yes
3/9/25	7.95			Yes
3/10/25	7.77			Yes
3/11/25	7.76			Yes
3/12/25	7.77	10.5		Yes
3/13/25	7.84			Yes
3/14/25	7.89	15		Yes
3/15/25	7.92			Yes
3/16/25	7.91			Yes
3/17/25	7.93			Yes
3/18/25	7.94			Yes
3/19/25	7.92	13.2		Yes
3/20/25	7.98			Yes
3/21/25	7.98	12		Yes
3/22/25	7.97			Yes
3/23/25	8.01			Yes
3/24/25	8.04			Yes
3/25/25	8.01			Yes
3/26/25	7.98	12.2		Yes
3/27/25	7.98			Yes
3/28/25	7.96	17.8		Yes
3/29/25	7.92			Yes
3/30/25	7.85			Yes
3/31/25	7.83			Yes

Entry Point

PWSID 4100359
System name Corbett Water District
Entry Point WTP-A Slow Sand Filter plant
Sample Period Mar-25

Number of excursionsn during this month 0
(count the number of days when any WQP was less than minimum required)

Total excursion during the previous 5 months 0
(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are culmulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7
Alk 8 Alkanlinity
PO4 Orthrophosphate
Other

Print Name Alivia Pence
Signature *Alivia Pence*
Date 4/4/2025