

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
4/1/25	8.32			Yes
4/2/25	8.16	16.8		Yes
4/3/25	7.73			Yes
4/4/25	7.6	12.3		Yes
4/5/25	7.68			Yes
4/6/25	7.7			Yes
4/7/25	8.3			Yes
4/8/25	7.95			Yes
4/9/25	7.74	17.4		Yes
4/10/25	7.75			Yes
4/11/25	7.81	16.7		Yes
4/12/25	7.73			Yes
4/13/25	7.79			Yes
4/14/25	7.72			Yes
4/15/25	7.59			Yes
4/16/25	7.4	13.8		Yes
4/17/25	7.52			Yes
4/18/25	7.51	14.1		Yes
4/19/25	7.85			Yes
4/20/25	7.79			Yes
4/21/25	8.11			Yes
4/22/25	7.78			Yes
4/23/25	7.79	16		Yes
4/24/25	7.8			Yes
4/25/25	7.82	17.2		Yes
4/26/25	7.91			Yes
4/27/25	7.9			Yes
4/28/25	7.81			Yes
4/29/25	7.85			Yes
4/30/25	7.64	19.7		Yes

Entry Point

PWSID 4100359
System name Corbett Water District
Entry Point WTP-A Slow Sand Filter plant
Sample Period Apr-25

Number of excursions during this month 0
(count the number of days when any WQP was less than minimum required)

Total excursion during the previous 5 months 0
(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are culmulative)

For OHA use only

Minimum Water Quality Parameters as set by		
pH	7	
Alk	8	Alkanlinity
PO4		Orthrophosphate
Other		

Print Name Alivia Pence

Signature Alivia Pence

Date 5/2/2025