

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
5/1/25	7.69			Yes
5/2/25	7.43	17.1		Yes
5/3/25	7.64			Yes
5/4/25	7.98			Yes
5/5/25	7.73			Yes
5/6/25	7.6			Yes
5/7/25	7.69	17.4		Yes
5/8/25	7.74			Yes
5/9/25	7.68	23		Yes
5/10/25	7.67			Yes
5/11/25	7.82			Yes
5/12/25	7.86			Yes
5/13/25	7.91			Yes
5/14/25	7.89	20.8		Yes
5/15/25	7.56			Yes
5/16/25	7.54	19		Yes
5/17/25	7.69			Yes
5/18/25	7.93			Yes
5/19/25	7.85			Yes
5/20/25	7.7			Yes
5/21/25	8.18	21.5		Yes
5/22/25	8.21			Yes
5/23/25	8.23	20.1		Yes
5/24/25	8.15			Yes
5/25/25	7.84			Yes
5/26/25	7.88			Yes
5/27/25	7.77			Yes
5/28/25	7.73	19.4		Yes
5/29/25	7.63			Yes
5/30/25	7.75	20		Yes
5/31/25	7.69			Yes

Entry Point

PWSID 4100359
System name Corbett Water District
Entry Point WTP-A Slow Sand Filter plant
Sample Period May-25

Number of excursions during this month 0
(count the number of days when any WQP was less than minimum required)

Total excursion during the previous 5 months 0
(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are culmulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7
Alk 8 Alkanlinity
PO4 Orthrophosphate
Other

Print Name Alivia Pence
Signature Alivia Pence
Date 6/2/2025