

# Water Quality Parameter Monitoring Form

## Lead and Copper Rule Corrsion Control

| Day     | pH   | Alk  | Phos other | Y/N |
|---------|------|------|------------|-----|
| 6/1/25  | 7.86 |      |            | Yes |
| 6/2/25  | 7.63 |      |            | Yes |
| 6/3/25  | 7.56 |      |            | Yes |
| 6/4/25  | 7.72 | 20.7 |            | Yes |
| 6/5/25  | 7.79 |      |            | Yes |
| 6/6/25  | 7.69 | 23.6 |            | Yes |
| 6/7/25  | 7.51 |      |            | Yes |
| 6/8/25  | 7.51 |      |            | Yes |
| 6/9/25  | 7.45 |      |            | Yes |
| 6/10/25 | 8.26 |      |            | Yes |
| 6/11/25 | 7.97 | 22.7 |            | Yes |
| 6/12/25 | 8.02 |      |            | Yes |
| 6/13/25 | 8.04 | 20.9 |            | Yes |
| 6/14/25 | 8.17 |      |            | Yes |
| 6/15/25 | 8.18 |      |            | Yes |
| 6/16/25 | 8.03 |      |            | Yes |
| 6/17/25 | 7.96 |      |            | Yes |
| 6/18/25 | 7.87 | 24   |            | Yes |
| 6/19/25 | 7.75 |      |            | Yes |
| 6/20/25 | 7.8  | 23.4 |            | Yes |
| 6/21/25 | 7.92 |      |            | Yes |
| 6/22/25 | 8.17 |      |            | Yes |
| 6/23/25 | 8.46 |      |            | Yes |
| 6/24/25 | 8.39 |      |            | Yes |
| 6/25/25 | 8.23 | 20.3 |            | Yes |
| 6/26/25 | 8.08 |      |            | Yes |
| 6/27/25 | 8.11 | 19.9 |            | Yes |
| 6/28/25 | 8.02 |      |            | Yes |
| 6/29/25 | 8.04 |      |            | Yes |
| 6/30/25 | 7.88 |      |            | Yes |

### Entry Point

PWSID 4100359  
System name Corbett Water District  
Entry Point WTP-A Slow Sand Filter plant  
Sample Period Jun-25

Number of excursions during this month 0  
(count the number of days when any WQP was less than minimum required)

Total excursion during the previous 5 months 0  
(Over 9 excursions in 6 months is a violation.  
Entry Point and Distribution excursions are culmulative)

For OHA use only

|                                            |   |                 |
|--------------------------------------------|---|-----------------|
| Minimum Water Quality Parameters as set by |   |                 |
| pH                                         | 7 |                 |
| Alk                                        | 8 | Alkanlinity     |
| PO4                                        |   | Orthrophosphate |
| Other                                      |   |                 |

Print Name Alivia Pence

Signature Alivia Pence

Date 7/2/2025