

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
7/1/25	7.8			Yes
7/2/25	7.8	21.9		Yes
7/3/25	7.81			Yes
7/4/25	8.04			Yes
7/5/25	7.83			Yes
7/6/25	7.93			Yes
7/7/25	7.82			Yes
7/8/25	7.84			Yes
7/9/25	7.5	20.9		Yes
7/10/25	7.55			Yes
7/11/25	7.49			Yes
7/12/25	7.38			Yes
7/13/25	7.34			Yes
7/14/25	7.44			Yes
7/15/25	7.56			Yes
7/16/25	7.53	26		Yes
7/17/25	7.52			Yes
7/18/25	7.55	26.7		Yes
7/19/25	7.58			Yes
7/20/25	7.68			Yes
7/21/25	7.79			Yes
7/22/25	7.8			Yes
7/23/25	7.78			Yes
7/24/25	7.74	24.3		Yes
7/25/25	7.74	23.3		Yes
7/26/25	7.71			Yes
7/27/25	7.8			Yes
7/28/25	7.82			Yes
7/29/25	7.75			Yes
7/30/25	7.77	25.9		Yes
7/31/25	7.74			Yes

Entry Point

PWSID 4100359

System name Corbett Water District

Entry Point WTP-A Slow Sand Filter plant

Sample Period Jul-25

Number of excursionsn during this month 0
(count the number of days when any WQP was less than minimum required)

Total excursion during the previous 5 months 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are culmulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7

Alk 8 Alkanlinity

PO4 Orthrophosphate

Other

Print Name Alivia Pence

Signature *Alivia Pence*

Date 8/4/2025