

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
8/1/25	7.76	28.2		Yes
8/2/25	7.73			Yes
8/3/25	7.77			Yes
8/4/25	7.9			Yes
8/5/25	7.96			Yes
8/6/25	7.95			Yes
8/7/25	7.96	29.7		Yes
8/8/25	8.02			Yes
8/9/25	8.06			Yes
8/10/25	8.02			Yes
8/11/25	7.94			Yes
8/12/25	7.96			Yes
8/13/25	7.99			Yes
8/14/25	8.01	29.6		Yes
8/15/25	8.27			Yes
8/16/25	8.28	30.2		Yes
8/17/25	8.25			Yes
8/18/25	8.23			Yes
8/19/25	8.17			Yes
8/20/25	7.89	23.3		Yes
8/21/25	7.91			Yes
8/22/25	7.88	24.9		Yes
8/23/25	7.7			Yes
8/24/25	7.7			Yes
8/25/25	7.84			Yes
8/26/25	7.85			Yes
8/27/25	7.86	27.4		Yes
8/28/25	7.85			Yes
8/29/25	7.88	28		Yes
8/30/25	7.97			Yes
8/31/25	7.97			Yes

Entry Point

PWSID	4100359
System name	Corbett Water District
Entry Point	WTP-A Slow Sand Filter plant
Sample Period	Aug-25
Number of excursionsn during this month (count the number of days when any WQP was less than minimum required)	0
Total excursion during the previous 5 months	0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are culmulative	
For OHA use only	
Minimum Water Quality Parameters as set by	
pH	7
Alk	8 Alkanlinity
PO4	Orthrophosphate
Other	
Print Name	<u>Alivia Pence</u>
Signature	<u><i>Alivia Pence</i></u>
Date	<u>9/2/2025</u>