

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
9/1/25	7.9			Yes
9/2/25	7.91			Yes
9/3/25	7.91	27.7		Yes
9/4/25	7.92			Yes
9/5/25	7.9	28.6		Yes
9/6/25	7.86			Yes
9/7/25	7.84			Yes
9/8/25	7.83			Yes
9/9/25	7.84			Yes
9/10/25	7.84	27.4		Yes
9/11/25	7.85			Yes
9/12/25	7.89	28.7		Yes
9/13/25	7.91			Yes
9/14/25	7.89			Yes
9/15/25	7.85			Yes
9/16/25	7.8			Yes
9/17/25	7.79			Yes
9/18/25	7.82	29.1		Yes
9/19/25	7.83			Yes
9/20/25	7.83			Yes
9/21/25	7.83			Yes
9/22/25	7.83			Yes
9/23/25	7.84			Yes
9/24/25	7.88			Yes
9/25/25	7.88			Yes
9/26/25	7.85	29.9		Yes
9/27/25	7.8			Yes
9/28/25	7.72			Yes
9/29/25	7.71			Yes
9/30/25	7.73			Yes

Entry Point

PWSID 4100359
System name Corbett Water District
Entry Point WTP-A Slow Sand Filter plant
Sample Period Sep-25

Number of excursionsn during this month 0
(count the number of days when any WQP was less than minimum required)

Total excursion during the previous 5 months 0
(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are culmulative)

For OHA use only

Minimum Water Quality Parameters as set by		
pH	7	
Alk	8	Alkanlinity
PO4		Orthrophosphate
Other		

Print Name Alivia Pence
Signature Alivia Pence
Date 10/2/2025