

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
10/1/24	7.76	29.1		Yes
10/2/24	7.84			Yes
10/3/24	7.91	28.6		Yes
10/4/24	8.03			Yes
10/5/24	8.06			Yes
10/6/24	8.03			Yes
10/7/24	7.92			Yes
10/8/24	7.84	29.1		Yes
10/9/24	7.83			Yes
10/10/24	7.87	30.2		Yes
10/11/24	7.9			Yes
10/12/24	7.92			Yes
10/13/24	7.89			Yes
10/14/24	7.94			Yes
10/15/24	7.98	33.8		Yes
10/16/24	7.98			Yes
10/17/24	7.95	33.4		Yes
10/18/24	7.91			Yes
10/19/24	7.86			Yes
10/20/24	7.85			Yes
10/21/24	7.87			Yes
10/22/24	7.88			Yes
10/23/24	7.91	28.9		Yes
10/24/24	7.54	28.4		Yes
10/25/24	7.92			Yes
10/26/24	7.86			Yes
10/27/24	7.81			Yes
10/28/24	7.82			Yes
10/29/24	7.86	31.4		Yes
10/30/24	7.94			Yes
10/31/24	7.99			Yes

Entry Point

PWSID 4100359
System name Corbett Water District
Entry Point WTP-A Slow Sand Filter plant
Sample Period Oct-25

Number of excursionsn during this month 0
(count the number of days when any WQP was less than minimum required)

Total excursion during the previous 5 months 0
(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are culmulative)

For OHA use only

Minimum Water Quality Parameters as set by		
pH	7	
Alk	8	Alkanlinity
PO4		Orthrophosphate
Other		

Print Name Alivia Pence
Signature Alivia Pence
Date 11/3/2025