

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
11/1/25	8.02			Yes
11/2/25	8.01			Yes
11/3/25	7.96			Yes
11/4/25	7.95			Yes
11/5/25	7.95	21.8		Yes
11/6/25	7.96			Yes
11/7/25	7.96	21.2		Yes
11/8/25	7.95			Yes
11/9/25	7.95			Yes
11/10/25	8			Yes
11/11/25	8.05			Yes
11/12/25	8.09	22.0		Yes
11/13/25	8.12			Yes
11/14/25	8.12	20.8		Yes
11/15/25	8.12			Yes
11/16/25	8.08			Yes
11/17/25	7.9			Yes
11/18/25	7.81			Yes
11/19/25	7.78	20.1		Yes
11/20/25	7.75			Yes
11/21/25	7.79	20.7		Yes
11/22/25	7.82			Yes
11/23/25	7.8			Yes
11/24/25	7.65			Yes
11/25/25	7.51			Yes
11/26/25	7.49	21.0		Yes
11/27/25	7.5			Yes
11/28/25	7.46			Yes
11/29/25	7.45			Yes
11/30/25	7.4			Yes

Entry Point

PWSID 4100359
 System name Corbett Water District
 Entry Point WTP-A Slow Sand Filter plant
 Sample Period Nov-25

Number of excursionsn during this month 0
 (count the number of days when any WQP was less than minimum required)

Total excursion during the previous 5 months 0

(Over 9 excursions in 6 months is a violation.
 Entry Point and Distribution excursions are culmulative

For OHA use only

Minimum Water Quality Parameters as set by		
pH	7	
Alk	8	Alkanlinity
PO4		Orthrophosphate
Other		

Print Name Alivia Pence

Signature Alivia Pence

Date 12/3/2025