

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
12/1/25	7.41			Yes
12/2/25	7.44			Yes
12/3/25	7.52	18.1		Yes
12/4/25	7.64			Yes
12/5/25	7.76	21.3		Yes
12/6/25	7.79			Yes
12/7/25	7.82			Yes
12/8/25	7.77			Yes
12/9/25	7.64			Yes
12/10/25	7.63	19		Yes
12/11/25	7.57			Yes
12/12/25	7.57	18		Yes
12/13/25	7.6			Yes
12/14/25	7.61			Yes
12/15/25	7.62			Yes
12/16/25	7.67			Yes
12/17/25	7.6	20		Yes
12/18/25	7.56			Yes
12/19/25	7.39	19.2		Yes
12/20/25	7.47			Yes
12/21/25	7.49			Yes
12/22/25	7.48			Yes
12/23/25	7.56	15.2		Yes
12/24/25	7.62			Yes
12/25/25	7.65	17		Yes
12/26/25	7.65			Yes
12/27/25	7.53			Yes
12/28/25	7.44			Yes
12/29/25	7.45			Yes
12/30/25	7.5	18.4		Yes
12/31/25	7.51			Yes

Entry Point

PWSID 4100359
 System name Corbett Water District
 Entry Point WTP-A Slow Sand Filter plant
 Sample Period Dec-25

Number of excursionsn during this month 0
 (count the number of days when any WQP was
 less than minimum required)

Total excursion during the previous 5 months 0
 (Over 9 excursions in 6 months is a violation.
 Entry Point and Distribution excursions are
 culmulative)

For OHA use only

Minimum Water Quality Parameters as set by
pH 7
Alk 8 Alkanlinity
PO4 Orthrophosphate
Other

Print Name Alivia Pence
 Signature Alivia Pence
 Date 1/8/2026