

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
1/1/26	7.8			Yes
1/2/26	7.5	19.8		Yes
1/3/26	7.57			Yes
1/4/26	7.65			Yes
1/5/26	8.05			Yes
1/6/26	8.19			Yes
1/7/26	7.86	19.8		Yes
1/8/26	7.68			Yes
1/9/26	7.86	19.2		Yes
1/10/26	8.02			Yes
1/11/26	8.06			Yes
1/12/26	8.08			Yes
1/13/26	7.96			Yes
1/14/26	7.85	20.5		Yes
1/15/26	7.82			Yes
1/16/26	7.7	17.9		Yes
1/17/26	7.6			Yes
1/18/26	7.89			Yes
1/19/26	7.9			Yes
1/20/26	7.77			Yes
1/21/26	7.63			Yes
1/22/26	7.76			Yes
1/23/26	8.07	16.8		Yes
1/24/26	7.72			Yes
1/25/26	8.01			Yes
1/26/26	8.1			Yes
1/27/26	8.02			Yes
1/28/26	7.52	21.3		Yes
1/29/26	7.52			Yes
1/30/26	7.6			Yes
1/31/26	7.52			Yes

Entry Point

PWSID 4100359  
 System name Corbett Water District  
 Entry Point WTP-A Slow Sand Filter plant  
 Sample Period Jan-26

Number of excursionsn during this month 0  
 (count the number of days when any WQP was  
 less than minimum required)

Total excursion during the previous 5 months 0  
 (Over 9 excursions in 6 months is a violation.  
 Entry Point and Distribution excursions are  
 culmulative)

For OHA use only

Minimum Water Quality Parameters as set by	pH	7	Alkalinity
	Alk	8	Orthrophosphate
	PO4		
	Other		

Print Name: Alivia Pence  
 Signature: *Alivia Pence*  
 Date: 2/2/2026