

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrosion Control

Day	pH	Alk	Phos other	Y/N
2/1/26	7.26			Yes
2/2/26	7.26			Yes
2/3/26	7.28			Yes
2/4/26	7.3	21		Yes
2/5/26	7.34			Yes
2/6/26	7.39	18.4		Yes
2/7/26	7.4			Yes
2/8/26	7.39			Yes
2/9/26	7.38			Yes
2/10/26	7.44			Yes
2/11/26	7.59	19.1		Yes
2/12/26	7.71			Yes
2/13/26	8.17	19.6		Yes
2/14/26	8.23			Yes
2/15/26	8.22			Yes
2/16/26	8.04			Yes
2/17/26	7.97			Yes
2/18/26	7.98	18.2		Yes
2/19/26	7.92			Yes
2/20/26	7.79	18.1		Yes
2/22/26	7.79			Yes
2/23/26	7.81			Yes
2/24/26	7.85			Yes
2/25/26	7.82			Yes
2/26/26	7.93	23		Yes
2/27/26	8.11	20.4		Yes
2/28/26	8.13			Yes

Entry Point

PWSID	4100359
System name	Corbett Water District
Entry Point	WTP-A Slow Sand Filter plant
Sample Period	Feb-26
Number of excursions during this month (count the number of days when any WQP was less than minimum required)	0
Total excursion during the previous 5 months	0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are culmulative	
For OHA use only	
Minimum Water Quality	
Parameters as set by	
pH	7
Alk	8 Alkalinity
PO4	Orthophosphate
Other	

Print Name

Alivia Pence

Signature

*Alivia Pence*

Date

3/6/2026