

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
3/1/26	8.34			Yes
3/2/26	8.28			Yes
3/3/26	8.04			Yes
3/4/26	7.91	21.4		Yes
3/5/26	8.13			Yes
3/6/26	8.09	20.1		Yes
3/7/26	7.94			Yes
3/8/26	7.78			Yes
3/9/26	8.03			Yes
3/10/26	8.07			Yes
3/11/26	7.96	19.7		Yes
3/12/26	7.77			Yes
3/13/26	7.75	19.9		Yes
3/14/26	8.08			Yes
3/15/26	8.21			Yes
3/16/26	8.2			Yes
3/17/26	8.18			Yes
3/18/26	8.12	15.8		Yes
3/19/26	8.06			Yes
3/20/26	8.02	18.9		Yes
3/21/26	7.99			Yes
3/22/26	8.19			Yes
3/23/26	8.15			Yes
3/24/26	7.64			Yes
3/25/26	7.33	19.9		Yes
3/26/26	7.52			Yes
3/27/26	7.64	18.8		Yes
3/28/26	7.3			Yes
3/29/26	7.33			Yes
3/30/26	7.64			Yes
3/31/26	7.7			Yes

Entry Point

PWSID 4100359
 System name Corbett Water District
 Entry Point WTP-A Slow Sand Filter plant
 Sample Period Mar-26
 Number of excursionsn during this month 0
 (count the number of days when any WQP was less than minimum required)
 Total excursion during the previous 5 months 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are culmulative)
 For OHA use only
 Minimum Water Quality Parameters as set by
 pH 7
 Alk 8 Alkanlinity
 PO4 Orthrophosphate
 Other

Print Name Alivia Pence
 Signature *Alivia Pence*
 Date 4/2/2026