

Water Quality Parameter Monitoring Form

Lead and Copper Rule Corrsion Control

Day	pH	Alk	Phos other	Y/N
9/1/21				
9/2/21				
9/3/21				
9/4/21				
9/5/21				
9/6/21				
9/7/21	9.04 & 8.45	22.1 & 26.6		Yes
9/8/21				
9/9/21				
9/10/21				
9/11/21				
9/12/21				
9/13/21				
9/14/21	8.4 & 8.37	24.1 & 21.9		Yes
9/15/21				
9/16/21				
9/17/21				
9/18/21				
9/19/21				
9/20/21				
9/21/21				
9/22/21				
9/23/21				
9/24/21				
9/25/21				
9/26/21				
9/27/21				
9/28/21				
9/29/21				
9/30/21				

Distribution readings
36120 HCRH and
43199 Larch mt rd

PWSID 4100359
System name Corbett Water District
Entry Point WTP-A Slow Sand Filter plant
Sample Period Sep-21

Number of excursionsn during this month 0
(count the number of days when any WQP was
less than minimum required)

Total excursion during the previous 5 months 7

(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
culmulative

For OHA use only

Minimum Water Quality		
Parameters as set by		
pH	7	
Alk	8	Alkanlinity
PO4		Orthrophosphate
Other		

Print Name David Jacob
Signature David Jacob
Date 10/6/2021