



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	7.24				Y
2	7.29				Y
3	7.30				Y
4	7.24				Y
5	7.21				Y
6	7.22				Y
7	7.24				Y
8	7.24				Y
9	7.26				Y
10	7.29				Y
11	7.22				Y
12	7.31				Y
13	7.29				Y
14	7.39				Y
15	7.30				Y
16	7.31				Y
17	7.26				Y
18	7.21				Y
19	7.25				Y
20	7.30				Y
21	7.31				Y
22	7.29				Y
23	7.21				Y
24	7.24				Y
25	7.36				Y
26	7.29				Y
27	7.31				Y
28	7.32				Y
29	7.44				Y
30	7.50				Y
31	7.44				Y

<<Have  
minimums  
been met  
for this day?

County: Tillamook Agency: C

**ENTRY POINT**

**A**

**PWS ID 4100367**

**HEBO JOINT WATER & SANITARY AUTH.**

Sample period: July 2022  
Month/Year

Number of excursions\* during this month: ①

(Over 9 excursions in 6 months is a violation. Entry  
Point and Distribution excursions are cumulative)

Reference

**Minimum Water Quality  
Parameters as set by State:**

pH 7.2

Print Name: Justin Hartford

Signature: [Signature]

Date: 08/01/2022

(No = N = Excursion) Total N's ①

Send to OHD within 10 days after end of sampling period

Oregon Health Division, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381