



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.54				Y
2	7.68				Y
3	7.63				Y
4	7.69	52			Y
5	7.68				Y
6	8.44				Y
7	8.87	40			Y
8	9.07	40			Y
9	9.21	80			Y
10	9.24	80			Y
11	9.27				Y
12	9.25	80			Y
13	9.26				Y
14	9.28	80			Y
15	9.34	80			Y
16	9.30	80			Y
17	9.19	80			Y
18	9.20	80			Y
19	9.20	80			Y
20	9.23	80			Y
21	9.10	80			Y
22	9.04	80			Y
23	9.13	80			Y
24	9.07	80			Y
25	8.80	80			Y
26	8.78	80			Y
27	8.90	80			Y
28	8.76	80			Y
29	8.71	80			Y
30	8.30	80			Y
31	8.22	80			Y

<<Have minimums been met for this day?

County: Tillamook Agency: C

ENTRY POINT

A

PWS ID 4100367

HEBO JOINT WATER & SANITARY AUTH.

Sample period: MAY / 2024
Month/Year

Number of excursions* during this month: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Reference

Minimum Water Quality Parameters as set by State:

pH 7.2

Print Name: _____
Signature: [Signature]
Date: 06/09/2024

(No = N = Excursion) Total N's 0