



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	8.00	600			Y
2	7.72				
3	7.79				
4	7.70				
5	7.60				
6	7.64				
7	7.50				
8	7.40	600			
9	7.38				
10	7.42				
11	7.25				
12	7.30				
13	7.41				
14	7.35				
15	7.40	40			
16	7.43				
17	7.46				
18	7.49				
19	7.51				
20	7.56				
21	7.57				
22	7.60	600			
23	7.58				
24	7.62				
25	7.66				
26	7.61				
27	7.62				
28	7.59				
29	7.60	600			
30	7.63				Y

<<Have minimums been met for this day?

County: Tillamook Agency: C

ENTRY POINT

A

PWS ID 4100367

HEBO JOINT WATER & SANITARY AUTH.

Sample period: June, 2024
Month/Year

Number of excursions* during this month: 1

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

Reference

Minimum Water Quality Parameters as set by State:

pH 7.2

Print Name: Justin Harford
Signature: [Signature]
Date: 07/09/2024

(No = N = Excursion) Total N's 1